

# IAPMO R&T OCEANA

1040 Dandenong Road, Carnegie VIC 3163 AUSTRALIA



IAPMO R&T Oceana is a product certification body which inspects and arranges for the independent laboratory testing of samples taken from the manufacturer's stock or from the market or a combination of both, to verify compliance of the requirements of applicable Standards and Specifications. This activity is coupled with periodic surveillance of the manufacturer's factory and any major subcontractor's site/s as well as the assessment of the manufacturer's Quality Assurance System. This certification is subject to the conditions set forth in the characteristics below and is not to be construed as any recommendation, assurance or guarantee by IAPMO R&T Oceana of the product acceptance by Authorities Having Jurisdiction.

## WATERMARK LICENCE

WaterMark Level 2

*IAPMO R&T Oceana hereby grants to:*

**Akatherm BV**

Industrieterrien 11, Panningen, Netherlands, 5981 NK

*the right to use the WaterMark in accordance with the "Procedures for Certification of Plumbing and Drainage Products - WaterMark Technical Specification" and the Plumbing Code of Australia only in respect of the certified product as described in the attached WaterMark Schedule. The Licence is granted subject to the rules governing the Watermark Certification Scheme and the Terms and Conditions for WaterMark Certification.*

*Evaluated to:*

**AS/NZS 4936 Air admittance valves (AAVs) for use in sanitary plumbing and drainage systems**

*Manufacturer:*

**Refer to Licence Holder**

**Licence No.:** WM-022830

(Certificate of Certification No.: IAPMO-WM-022830-I01-R00)

**Certified Date:**

31 July 2018

**Issue Date:** 31 July 2018

**Expiry Date:**

30 July 2021

A handwritten signature in cursive script that reads "Russ Chaney".

Chief Executive Officer of the IAPMO Group

This WaterMark certification is for the period indicated herein and is void after the date shown above. Any change in material, manufacturing process, marking or design without having first obtained the approval of IAPMO R&T Oceana, or any evidence of non-compliance with applicable Standards, Specifications or of inferior workmanship, may be deemed sufficient cause for revocation of this certification. Reproduction of or reference to this certificate for advertising purposes may be made only by specific written permission of IAPMO R&T Oceana. Any alteration of this certificate could be grounds for revocation of this certification.



# WATERMARK SCHEDULE - LEVEL 2



<b>Licence Holder:</b> Akatherm BV <b>Address :</b> Industrierrein 11 Panningen, 5981 NK The Netherlands	<b>Licence No.:</b> WM-022830 <b>Issue Date:</b> 31-Jul-18 <b>Expiry Date:</b> 30-Jul-21 <b>First Certified:</b> 31-Jul-18 <b>Standard/s:</b> AS/NZS 4936:2002 Air admittance valves (AAVs) for use in sanitary plumbing and drainage systems
<b>Manufacturer:</b> Refer to Licence Holder	

Std/Spec: AS/NZS 4936:2002

Licence No.: WM-022830

Brand Name	Model Name	Model ID	Product Type	Product Description	End Connection	Rated Capacity	Flow Rate	Material
Studor	Mini-Vent	49017, 49018	Air admittance (induct/one way)	DN 32 Air Admittance Valve	Flexible push-fit	94 Fixture Units (Group)	7.5 L/s	ABS
Studor	Mini-Vent	49009, 49010, 49018	Air admittance (induct/one way)	DN 40 Air Admittance Valve	R1-1/2	94 Fixture Units (Group)	7.5 L/s	ABS
Studor	Mini-Vent	49017, 49018	Air admittance (induct/one way)	DN 50 Air Admittance Valve	Flexible push-fit	94 Fixture Units (Group)	7.5 L/s	ABS
Studor	Redi-Vent	49202	Air admittance (induct/one way)	DN 32 Air Admittance Valve	Flexible push-fit	10 Fixture Units (Group)	2.4 L/s	ABS
Studor	Redi-Vent	49202	Air admittance (induct/one way)	DN 40 Air Admittance Valve	R1-1/2	10 Fixture Units (Group)	2.4 L/s	ABS
Studor	Redi-Vent	49202	Air admittance (induct/one way)	DN 50 Air Admittance Valve	Flexible push-fit	10 Fixture Units (Group)	2.4 L/s	ABS
Studor	Maxi-Vent	49112	Air admittance (induct/one way)	DN 80 Air Admittance Valve	Flexible push-fit	1728 Fixture Units (Group) 125 Fixture Units (Stack)	32 L/s	ABS
Studor	Maxi-Vent	49112	Air admittance (induct/one way)	DN 100 Air Admittance Valve	Flexible push-fit	1728 Fixture Units (Group) 125 Fixture Units (Stack)	32 L/s	ABS
Studor	Tec-Vent	49209	Air admittance (induct/one way)	DN 40 Air Admittance Valve	R1-1/2	94 Fixture Units (Group)	7.5 L/s	Flame retardant polycarbonate (unverified)

END RECORD

END RECORD

Chief Executive Officer of the IAPMO Group